




Test Report Summary

| Product Information | |
|---|---|
| Licence Number: | 217741 |
| Licensee: | MADEL AIR TECHNICAL DIFUSSION |
| Product Identification | ZITY+ZEBRA |
| Test Specifications | |
| Tested Application: | Variable air volume system (without h/c coil) |
| Temperature Sensor | |
| - Type: | MADEL_ZEBRA NTC10K 0.13 |
| - Time Constant: | 0.13 Mins |
| Actuator Identification | ZRAIS100 (Madel) |
| - Type: | None |
| Valve Identification | |
| - Characteristic | None |
| AV Acronym | 24Vdc/**/**/**/** |
| Fan Speed (For Fan Coil Applications) | |
| - Characteristic | None |
| Test Result | |
| Temperature Control Accuracy C _A according EN 15500 | Heating - 0.3 K Cooling - 0.4 K |

20 February 2018
Brussels


 Managing Director Dr. Peter Hug
 eu.bac