




Test Report Summary

Product Information	
Licence Number:	217741
Licensee:	MADEL AIR TECHNICAL DIFUSSION
Product Identification	ZITY+ZOE
Test Specifications	
Tested Application:	Variable air volume system (without h/c coil)
Temperature Sensor	
- Type:	MADEL_ZOE NTC10K 0.1
- Time Constant:	0.1 Mins
Actuator Identification	ZRAIS100 (Madel)
- Type:	None
Valve Identification	None
- Characteristic	None
AV Acronym	24Vdc/**/**/**/**
Fan Speed (For Fan Coil Applications)	
- Characteristic	None
Test Result	
Temperature Control Accuracy C _A according EN 15500	Heating - 0.3 K Cooling - 0.3 K

20 February 2018
Brussels


 Managing Director Dr. Peter Hug
 eu.bac